

#11: WASTE WATER

CORE METRIC FOR CATEGORY A & B & C CITIES THAT HAVE A WASTE WATER COLLECTION SYSTEM

Bold, green font indicates data elements that are eligible to be recognized at Step 5 if improvement is demonstrated.

DATA ELEMENTS

- 11.1 Residential gallons of waste water produced per person per day
- 11.2 Business gallons produced per job per day
- 11.3 Annual energy used per million gallons treated (MMBtus/million gallons) (report only if you own a treatment facility)
- 11.4 Annual operating cost in dollars per million gallons treated (report only if you own a treatment facility)
- 11.5 **Ratio of Inflow & Infiltration volume to total volume entering collection system**

DEFINITIONS

- **If your city owns or is part-owner or jointly controls a waste water treatment plant (WWTP)**, then report all the data elements in this metric. (Element 11.1-11.5)
- **Cities that do not own and operate a WWTP** (most cities in the 7-county metro area; some greater MN cities) should report residential and business gallons, I & I (inflow and infiltration) data, and only energy and cost data related to the part of a sewer system they do operate, such as lift stations. (Elements 11.1, 11.2, 11.5, and partial 11.3 and 11.4)
- **If your city is entirely served by septic systems** then this is not a Core metric for your city. If you track a metric about septic systems in your city, GreenStep would appreciate your reporting that in the notes field on the Step 4 reporting form.
- **Residential and business gallons** exclude accounts outside the city. Business gallons include waste water treated from commercial, industrial & institutional accounts. (Elements 11.1 and 11.2)
- **Energy and cost per million gallons treated** should cover total inflow to the plant, from accounts inside and outside the city. (Elements 11.3 and 11.4)
- **Report energy in MMBtu** = million British Thermal Units of energy. Electricity (tracked in kilowatt-hours: kWh) and liquid fuels (generally tracked in BTUs) should be converted to the common unit MMBtu. (Element 11.3)
- **Inflow and Infiltration (I & I) measures clear water “leakage” into the waste water system** (conveyance pipes, and possibly part of the WWTP) – typically rain water – and represents a volume of liquid that does not need to be treated at the WWTP. Minimizing I & I effectively adds treatment capacity for what needs to be treated. (Element 11.5)
- **Alternative metrics:** If you have been gathering or want to gather different data, report those and explain why they are a better fit for your city. For example:
 - The ENERGY STAR® score compares the predicted energy use of a waste water plant to its actual energy use to yield a 1 to 100 percentile ranking of performance, relative to plants across the nation.
 - System operators tend to use one of four other measurements, typically measured in less-than-yearly evaluations of the sewer system, which should also be re reported if tracked in your city:
 - Gallons/day/foot of sewer pipes
 - Gallons/day/inch-mile of pipe

Minnesota GreenStep Cities Performance Metrics for Recognition at Steps 4 and 5

- Million gallons/day/1,000 feet of pipe
- Million gallons/day/acre of land served by sewer pipe

DATA SOURCES

- WWTP permit data submitted to the MN Pollution Control Agency
- City records
- Infrastructure Stress Transparency Tool (MN State Auditor): <https://www.auditor.state.mn.us/maps/>
- Energy Star Portfolio Manager (if the city is using this tracking system)
<https://www.energystar.gov/buildings/tools-resources/energy-star-score-wastewater-treatment-plants>
- The B3 system: <https://mn.b3benchmarking.com>
- Jobs data from North American Industry Classification System (NAICS) and the Quarterly Census of Employment Wages (QCEW) - <http://www.positivelyminnesota.com/apps/lmi/qcew/ResultsDisp.aspx> Use "Total of All Ownerships" and "Total, All Industries" and Quarter 2 data (tends to be least affected by seasonal fluctuation).

CALCULATION AND PUBLIC REPORTING

- **Annual measurement and reporting** for these elements is for the calendar year before the reporting year. If I & I has not been calculated in the last year, simply report the last I & I percent and note the calendar year during which the percent was calculated. (Elements 11.1-11.5)
- **If a city purchases some of its waste water services** from another city/entity for some residential/commercial addresses, do not average in data from that other system: report numbers based on the city utility data only. (Elements 11.1-11.-5)
- **Residential and businesses gallons** use the past year of data (usually estimated) so that an average daily waste water flow is reported for residential accounts and for business accounts. These numbers are normalized, respectively, by your latest city population number and your latest total city jobs number so as to identify whether in aggregate residences and businesses are higher or lower waste water services users. (Elements 11.1 and 11.2)
- **MMBtu /million gallons** = energy used to run the complete city waste water system (treatment plan and off-site pumps). Systems using electricity (tracked in MMWh) and liquid fuels (generally tracked in Btus) should convert all energy use to the common Element MMTus. Use data from the calendar year before the reporting year. For energy conversions use http://www.eia.gov/Energyexplained/index.cfm?page=about_energy_conversion_calculator
- **\$/million gallons** = the total operating cost (energy, labor, maintenance, depreciation) to treat each one million gallons of waste water, measured as it enters the WWTP. Use data from the calendar year before the reporting year. Include depreciation costs but exclude one-time capital costs. Note that the State Auditor's Infrastructure Tool reports three data points for a city's sewer enterprise fund: very useful for fiscal sustainability but different than this GreenStep Element. (Element 11.3)
- **Annual operating cost in dollars per million gallons treated:** total energy (dollars), divide by total gallons treated over the past 12 months, and divide by 1,000,000. (Element 11.4)
- **While % I & I highlights** the magnitude of any I & I problems, system operators tend to use one of four other metrics, which should also be reported in the notes section of the GreenStep reporting form if one or more of them is tracked in your city:
 - Gallons / day / foot of sewer pipes
 - Gallons / day / inch-mile of pipe
 - Million gallons / day / 1,000 feet of pipe

Minnesota GreenStep Cities
Performance Metrics for Recognition at Steps 4 and 5

- Million gallons / day / acre of land served by sewer pipes
(Element 11.5)

RATIONALE

Waste water treatment plants are highly regulated and must report various detailed reports and measures to the State of Minnesota. Flow volumes, however, are not regulated but affect overall pollutant loading on bodies of water receiving treated effluent from WWTPs. This GreenStep metric also includes an energy measure, often overlooked in city improvement processes, and defines key data to help improve demand-side management of a city's treatment plant and waste water system.

Conserving water in and reducing wastewater flows from homes and businesses effectively adds capacity to a city's waste water infrastructure at generally a cost cheaper than expanding a WWTP. Cities can promote such actions, which are found in several GreenStep best practices, including Existing Buildings and Green Business Development. Benefits include reducing carbon emissions from wastewater systems, which can easily make up one quarter of the city operations' carbon footprint.

I & I expenditures in the 7-county metro area cities during 2009 were an estimated \$12 million. Without annual expenditures incentivized by the metro sewer authority, the cost to add metro wastewater interceptor and treatment capacity to handle the excess flow from I & I was estimated to exceed \$900 million.

STEP 5 TARGETS

Individual cities are best equipped to set realistic goals for metric improvement, as every city's mix of businesses and residences and geography is different. Any improvement in the metrics is beneficial. That said, the Minnesota Technical Assistance Program (MnTAP) and Wisconsin's Focus on Energy have benchmarked (during 2011 and 2006, respectively) energy use for dozens of treatment plants of differing types. I & I rates under 6% are considered achievable at reasonable cost.

NEED HELP? CONTACT

Karl DeWahl, best practice advisor for WWTPs, Minnesota Technical Assistance Program
612-624-4645 or dewah001@umn.edu

February 2017